

Daily Inspection Log For Tank Systems

By initialing in the box below I certify that I have conducted an inspection in accordance with 22 CCR Section 66265.195(a). Specifically this inspection included inspection of the following items:

- 1) Overfill /spill control equipment
- 2) Aboveground portions of the tank system to detect corrosion or releases of waste
- 3) Data gathered from monitoring equipment and leak detection equipment to ensure that the tank system is being operated according to its design;
- 4) The construction materials and the area immediately surrounding the externally accessible portion of the tank system including secondary containment structures to detect erosion or signs of releases of hazardous waste.
- 5) For uncovered tanks, the level of waste in the tank, to ensure compliance with section 66265.194(b)(3).
- 6) Label - legible and complete

Content: _____ Tank Size: _____ Location: _____

	Jan.	Feb.	Mar.	Apr.	May	June	July	Aug.	Sep.	Oct.	Nov.	Dec.
1												
2												
3												
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												
20												
21												
22												
23												
24												
25												
26												
27												
28												
29												
30												
31												

Name of Person Responsible For Inspection: _____ Inspection Year: _____